


Steven V. Hubbard
Superintendent of Schools

2809 Cincinnatus Rd
Cincinnatus, NY 13040



Cincinnati Central School District

607-863-4069/fax 607-863-4109
shubbard@cc.cnyric.org

November 15, 2016

Dear Parents/Guardians,

As you may be aware, Gov. Andrew Cuomo signed a new law on September 6, 2016 that requires public school districts to test for lead levels in all water outlets currently or potentially used for drinking or cooking. In accordance with the new law, this letter is being sent to inform you about recent water testing completed across the Cincinnati Central School District.

The district has taken water samples from 152 outlets within the district. All school buildings were tested. Under the state's standard, water sources that could potentially be used for drinking or cooking that are found to have lead levels greater than 15 parts per billion (0.015) are to be taken out of service until remediated. A sink that is important for handwashing may remain in service and labeled not for consumption until remediated.

Of 152 areas tested, 24 had readings above 0.015 after initial testing. None of the 24 readings above the 0.015 standard were drinking fountains. Other than the areas identified below all other areas tested came in within the limits for acceptable drinking water.

<u>Location</u>	<u>Result</u>	<u>Remediation</u>
Elementary Principal's Conf. Room sink	0.0191	Signage – <i>Do Not Drink</i> , Fixture will be replaced
Room 102 sink	0.0151	Fixture shut off and will be replaced
Room 102 sink	0.506	Fixture shut off and will be replaced
Room 103 sink	0.0211	Fixture shut off and will be replaced
Room 106 sink	0.0187	Fixture shut off and will be replaced
Room 111 sink	0.588	Fixture shut off and will be replaced
Kitchen sink	0.0195	Signage – <i>Do Not Drink/No Food Preparation</i> , Fixture will be replaced
Kitchen sink	0.0502	Signage – <i>Do Not Drink/No Food Preparation</i> , Fixture will be replaced
Kitchen sink	0.0295	Signage – <i>Do Not Drink/No Food Preparation</i> , Fixture will be replaced
Kitchen sink	0.883	Signage – <i>Do Not Drink/No Food Preparation</i> , Fixture will be replaced
Room 202 sink	0.0168	Signage – <i>Do Not Drink</i> , Fixture will be replaced


Boys Bathroom Sink/Lg. gym hallway	0.0540	Signage – <i>Do Not Drink</i> , Fixture will be replaced
Girls Bathroom Sink/Lg. gym hallway	0.0228	Signage – <i>Do Not Drink</i> , Fixture will be replaced
Girls Bathroom Sink/Lg. gym hallway	0.0152	Signage – <i>Do Not Drink</i> , Fixture will be Replaced
Handicap Bathroom Sink/Lg. gym hallway	0.131	Signage – <i>Do Not Drink</i> , Fixture will be replaced
Room 226 sink	0.0154	Fixture shut off and will be replaced
Room 230 Home & Careers sink	0.0217	Signage – <i>Do Not Drink</i> , Fixture will be replaced
Library Bathroom sink	0.0189	Signage – <i>Do Not Drink</i> , Fixture will be replaced
Office Bathroom sink (Room 306)	0.0202	Signage – <i>Do Not Drink</i> , Fixture will be replaced
Staff Bathroom sink	0.0190	Signage– <i>Do Not Drink</i> , Fixture will be replaced
Room 321 sink	0.0260	Fixture shut off and will be replaced
Room 329 Science sink	0.0505	Signage – <i>Do Not Drink</i> , Fixture will be replaced
Nurse’s office sink	0.0448	Fixture shut off and will be replaced
High School Principal’s office sink	0.0165	Signage – <i>Do Not Drink</i> , Fixture will be replaced

Follow-up testing will be performed to ensure safe levels before the above outlets are returned to service.

Additional information and water testing results are available on the district website at www.cc.cnyric.org.

Please contact me if you have any questions.

Sincerely,



Steven V. Hubbard
Superintendent of Schools